



Declaration of Performance – DOP0000005 **According to Construction Products Regulation EU N° 305/2011**

1. Unique Product identification code(s):

C4403AIR, C4403A2, C4403B, C4416, C4414, C4408, C4408D

2. Type, batch or serial number(s) or any other element allowing identification of the construction product(s) as required pursuant to Article 11(4):

ActiV conventional Class A1R rate of rise heat detector (C4403A1R)
ActiV conventional Class A2 fixed temperature heat detector (C4403A2)
ActiV conventional Class B fixed temperature heat detector (C4403B)
ActiV conventional optical smoke detector (C4416)
ActiV conventional multi-sensor fire detector, low optical sensitivity with class A2 heat detection (C4414)
ActiV conventional non-diode detector base (C4408)
ActiV conventional diode detector base (C4408D)

3. Intended use or uses of the construction product(s), in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Models C4403AIR, C4403A2, C4403B and C4416:
Heat detectors – point detectors - for use in Fire detection and fire alarm systems to
EN 54-5:2000 + A1: 2002

Models C4414 and C4416:
Smoke detectors - Point detector using scattered light, transmitted light or ionization -
for use in Fire detection and fire alarm systems to EN54-7: 2000 + A1: 2002 + A2: 2006

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Computationics Limited (C-TEC)
Challenge Way, Martland Park, Wigan WN5 0LD. United Kingdom
Tel: 01942 322744. Fax: 01942 829867

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. Notified body, in the case of the declaration of performance concerning a construction product covered by a harmonized standard:

Intertek Testing & Certification Limited (notified body number 0359)
Intertek House, Cleeve Road, Leatherhead,
Surrey KT22 7SB. United Kingdom.



has performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

0359-CPD-0183

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9(a). Declared performance applicable to models C4403AIR, C4403A2, C4403B and C4416:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Performance	Clauses in EN54-5:2000 + A1:2002	Notes
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2	6.2 applies to C4403A1R only
Operational reliability	Pass	4.4 to 4.11	
Tolerance of supply voltage	Pass	5.7	
Durability of operational reliability (temperature resistance)	Pass	5.9, 5.10	
Durability of operational reliability (vibration resistance)	Pass	5.14 to 5.17	
Durability of operational reliability (humidity resistance)	Pass	5.11, 5.12	
Durability of operational reliability (corrosion resistance)	Pass	5.13	
Durability of operational reliability (electrical stability)	Pass	5.18	
<i>Note: ActiV detector model number C4414 (Multi-Sensor Fire Detector) also has a declared performance in section 9(b) relating to EN54-7:2000 + A1:2002 +A2:2006</i>			



9(b). Declared performance applicable to models C4414 and C4416:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Performance	Clauses in EN54-7:2000 + A1:2002 +A2:2006
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18
Operational reliability	Pass	4.2 to 4.7, 4.9 to 4.11
Tolerance to supply voltage	Pass	5.5
Durability of operational reliability and response delay; temperature resistance	Pass	5.8, 5.9
Durability of operational reliability; vibration resistance	Pass	5.13 to 5.16
Durability of operational reliability; humidity resistance	Pass	5.10, 5.11
Durability of operational reliability; corrosion resistance	Pass	5.12
Durability of operational reliability; electrical stability	Pass	5.17
<i>Note: ActiV detector model number C4414 (Multi-Sensor Fire Detector) also has a declared performance in section 9(a) relating to EN54-5:2000 + A1:2002</i>		

10. Empowered Signatory of Company

Name: Andrew D Scott

Position: Director

Signature:

Date: 29 August 2013.



Deklaracja właściwości użytkowych - DOP0000005

Zgodnie z Rozporządzeniem w sprawie wyrobów budowlanych UE NR 305/2011

1. Unikalne kody identyfikacyjne produktu:

C4403AIR, C4403A2, C4403B, C4416, C4414, C4408, C4408D

2. Typ, partia lub numer seryjny/numery seryjne lub jakikolwiek inny element umożliwiający identyfikację wyrobu budowlanego / wyrobów budowlanych zgodnie z Artykułem 11(4):

ActiV konwencjonalny wskaźnik wzrostu temperatury klasy A1R (C4403A1R)
ActiV konwencjonalny czujnik ciepła do stałej temperatury klasy A2 (C4403A2)
ActiV konwencjonalny czujnik ciepła do stałej temperatury klasy B (C4403B)
ActiV konwencjonalny optyczny czujnik dymu (C4416)
ActiV konwencjonalny wielosensoryczny czujnik ognia, niska czułość optyczna z wykrywaniem ciepła klasy A2 (C4414)
ActiV konwencjonalna nie-diodowa podstawa wykrywacza (C4408)
ActiV konwencjonalna diodowa podstawa wykrywacza (C4408D)

3. Zamierzone zastosowanie lub zastosowania wyrobu budowlanego lub wyrobów budowlanych zgodnie z obowiązującą zharmonizowaną specyfikacją techniczną, tak jak przewidział producent:

Modele C4403AIR, C4403A2, C4403B i C4416:

Wykrywacze ciepła - czujki punktowe - do użytku w systemach wykrywania i sygnalizacji pożaru według EN 54-5: 2000 + A1: 2002

Modele C4414 i C4416:

Czujki dymu - Detektor punktowy wykorzystujący światło rozproszone, przekazane światło lub jonizację - do stosowania w systemach wykrywania i sygnalizacji pożaru według EN54-7: 2000 + A1: 2002 + A2: 2006.

4. Nazwa, zarejestrowana nazwa handlowa lub zarejestrowany znak towarowy i adres kontaktowy producenta zgodnie z Artykułem 11(5):

Comptonics Limited (C-TEC)

Challenge Way, Martland Park, Wigan WN5 0LD. Zjednoczone Królestwo

Tel: 01942 322744. Faks: 01942 829867

5. W stosownych przypadkach, nazwa i adres kontaktowy upoważnionego przedstawiciela, którego mandat obejmuje zadania określone w Artykule 12 (2):

Nie dotyczy

6. System lub systemy oceny i weryfikacji stałości właściwości użytkowych wyrobu budowlanego, jak określono w Załączniku V:

System 1

7. Jednostka notyfikowana, w przypadku deklaracji właściwości użytkowych dotyczącej wyrobu budowlanego objętego normą zharmonizowaną:

Intertek Testing & Certification Limited (jednostka notyfikowana nr 0359)

Intertek House, Cleeve Road, Leatherhead,

Surrey KT22 7SB. Zjednoczone Królestwo.





[Firma C-TEC] przeprowadziła badanie typu oraz wstępną inspekcję zakładu produkcyjnego i zakładowej kontroli produkcji z ciągłym nadzorem, oceną i zatwierdzeniem zakładowej kontroli produkcji w systemie 1 i wydała następujący certyfikat stałości właściwości użytkowych:

0359-CPD-0183

8. W przypadku deklaracji właściwości użytkowych dotyczącej wyrobu budowlanego, dla którego wydano Europejską ocenę techniczną:

Nie dotyczy, patrz punkt 7

9(a). Deklarowane działanie dotyczące modeli C4403AIR, C4403A2, C4403B i C4416:

Wszystkie wymagania, w tym wszystkie Podstawowe właściwości oraz odpowiednie działanie dla zamierzonego zastosowania lub zastosowań wskazanych w punkcie 3 powyżej, zostały określone zgodnie z opisem w hEN [normie zharmonizowanej] wymienionym w poniższej tabeli.

Podstawowe właściwości	Działanie	Klauzule w EN54-5:2000 + A1:2002	Uwagi
Nominalne warunki aktywacji / Czulość, Opóźnienie reakcji (czas reakcji) i Działanie w warunkach pożaru.	Zaliczono	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2	6.2 odnosi się tylko do C4403A1R
Niezawodność działania	Zaliczono	4.4 to 4.11	
Tolerancja na napięcie zasilania	Zaliczono	5.7	
Trwałość niezawodności eksploatacyjnej (odporność na temperaturę)	Zaliczono	5.9, 5.10	
Trwałość niezawodności eksploatacyjnej (odporność na wibracje)	Zaliczono	5.14 to 5.17	
Trwałość niezawodności eksploatacyjnej (odporność na wilgoć)	Zaliczono	5.11, 5.12	
Trwałość niezawodności eksploatacyjnej (odporność na korozję)	Zaliczono	5.13	
Trwałość niezawodności eksploatacyjnej (stabilność elektryczna)	Zaliczono	5.18	

Uwaga: Model czujnika ActiV numer C4414 (wielosensoryczny czujnik ognia) również posiada deklarowane działanie w sekcji 9 (b) odnoszące się do EN54-7.2000 + A1: 2002 + A2: 2006



